

Table 1

WNSL-W1-2311.01/2021 Appendix B.1 Phase 1 Release Limits for Liquid Effluent		Monthly Mean Concentration Results from Sample Analysis		
Parameter	Maximum Monthly Mean Concentration	2015 January	2015 February	2015 March
Radium-226 (Becquerels per litre)	0.37	0.23 ¹	0.22 ¹	0.13 ²
pH	Between 6.0 and 9.0	7.77 ¹	7.60 ¹	7.60 ¹
Toxicity Testing ³	Effluent cannot be toxic	PASS	PASS	PASS

1 – Radium-226 and pH results based on analyses of four samples

2 – 2015 March Radium-226 result based on analysis of one sample

3 – Toxicity testing results based on one monthly sample