

Table 1

WNSL-W1-2311.01/2022 Appendix B Phase 1 Release Limits for Liquid Effluent		Monthly Mean Concentration Results from Sample Analysis		
Parameter	Maximum Monthly Mean Concentration	2015 April ¹	2015 May ²	2015 June ³
Radium-226 (Bq/L)	0.37	0.0376	0.0487	0.040
Arsenic (mg/L)	0.50	0.0034	0.0063	0.009
pH	Between 6 and 9	7.66	7.79	7.84
Toxicity Testing	Effluent cannot be toxic	PASS	PASS	PASS

1 – Based on analyses of five samples

2 – Based on analyses of three samples

3 – Based on analyses of three samples

Toxicity testing results based on one monthly sample