

<b>WNSL-W1-2311.01/2022 Appendix B Phase 1 Release Limits for Liquid Effluent</b>		<b>Monthly Mean Concentration Results from Sample Analysis</b>		
<b>Parameter</b>	<b>Maximum Monthly Mean Concentration</b>	<b>2015 July <sup>1</sup></b>	<b>2015 August <sup>2</sup></b>	<b>2015 September <sup>3</sup></b>
Radium-226 (Bq/L)	0.37	0.035	0.029	0.040
Arsenic (mg/L)	0.50	0.0125	0.0213	0.0163
pH	Between 6 and 9	7.88	7.95	7.83
Toxicity Testing <sup>4</sup>	Effluent cannot be toxic	PASS	PASS	PASS

1 – Based on analyses of four samples

2 – Based on analyses of three samples

3 – Based on analyses of three samples

4 – Toxicity testing results based on one monthly sample