

Table 1

WNSL-W1-2311.01/2021 Appendix B.1 Phase 1 Release Limits for Liquid Effluent		Monthly Mean Concentration Results from Sample Analysis		
Parameter	Maximum Monthly Mean Concentration	2016 January ¹	2016 February ¹	2016 March ²
Radium-226 (Becquerels per litre)	0.37	0.18	0.19	0.10
pH	Between 6.0 and 9.0	7.77	7.75	7.81
Toxicity Testing ³	Effluent cannot be toxic	PASS	PASS	PASS

1 – Radium-226 and pH results based on analyses of four samples

2 – Radium-226 and pH results based on analyses of five samples

3 – Toxicity testing results based on one sample for January, one sample for February and two samples for March