

Table 1– 2017 April to June Effluent and Toxicity Results

WNSL-W1-2311.01/2021 Appendix B.1 Phase 1 Release Limits for Liquid Effluent		Monthly Mean Concentration Results from Sample Analysis		
Parameter	Maximum Monthly Mean Concentration	2017 April ¹	2017 May ³	2017 June ¹
Radium-226 (Bq/L)	0.37	<0.005	<0.005	<0.005
pH	Between 6.0 and 9.0	7.35	7.64	7.66
Toxicity Testing ²	Effluent cannot be toxic	PASS	PASS	PASS

1 – Radium-226 and pH results based on analyses of four samples

2 – Toxicity testing results based on one sample

3 – Radium-226 and pH results based on analyses of five samples