

Table 1– 2017 January to March Effluent and Toxicity Results

WNSL-W1-2311.01/2021 Appendix B.1 Phase 1 Release Limits for Liquid Effluent		Monthly Mean Concentration Results from Sample Analysis		
Parameter	Maximum Monthly Mean Concentration	2017 January ¹	2017 February ³	2017 March ¹
Radium-226 (Bq/L)	0.37	<0.005	<0.005	<0.005
pH	Between 6.0 and 9.0	7.39	6.93	7.05
Toxicity Testing ²	Effluent cannot be toxic	PASS	PASS	PASS

1 – Radium-226 and pH results based on analyses of four samples

2 – Toxicity testing results based on one sample

3 – Radium-226 and pH results based on analyses of five samples